

【施設維持管理情報 令和7年】

7月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	171	168	170	1,000	1,000	1,000	1.0	0.0	0.0
2 水	169	168	169	1,000	999	1,000	0.0	0.0	0.0
3 木		170	171		1,000	998		3.0	0.0
4 金	168	171	170	1,000	1,000	1,001	1.0	1.0	0.0
5 土	172	171	170	1,000	1,000	999	0.0	0.0	0.0
6 日									
7 月	171	170	168	999	1,000	1,001	2.0	0.0	0.0
8 火	170	171	172	1,000	1,000	1,000	0.0	0.0	0.0
9 水	168	170	171	1,000	1,000	1,000	5.0	0.0	0.0
10 木		170	171		1,000	1,000		1.0	0.0
11 金	170	171	172	1,000	1,000	999	0.1	0.0	0.0
12 土		168	170		998	1,000		0.0	0.0
13 日									
14 月	171	170	171	1,000	1,000	998	0.0	0.0	0.0
15 火		168	169		1,000	1,000		0.0	0.0
16 水	170	170	171	1,000	1,000	1,000	13.0	0.0	0.0
17 木		170	171		998	999		0.0	0.0
18 金	171	171	169	1,000	1,000	1,000	0.0	0.0	0.0
19 土									
20 日									
21 祝									
22 火	170	169	172	1,000	1,000	1,000	0.0	0.0	0.0
23 水	171	171	170	1,001	1,000	999	0.0	0.0	0.0
24 木		170	168		1,000	1,000		0.0	0.0
25 金	171	170	171	1,000	1,000	1,000	3.0	1.0	0.0
26 土	170	169	171	1,000	1,000	990	0.0	0.0	0.0
27 日									
28 月	169	170	170	1,000	1,000	999	1.0	0.0	0.0
29 火		171	172		1,000	1,000		0.0	0.0
30 水	171	169	170	1,000	1,000	1,000	2.0	0.0	0.0
31 木		170	171		998	1,000		0.0	0.0