【施設維持管理情報 令和7年】

9月

項目			集塵器に流入する燃焼ガ スの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
時間日		間	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
	1	月	171	170	172	1,000	1,000	999	0.0	0.0	0.0
	2	火	.,,	169	171	.,	1,000	1,000	0.0	1.0	0.0
	3	水	171	172	170	1,000	999	1,000	0.0	0.0	0.0
	4	木	172	172	171	1,000	1,000	1,000	1.0	0.0	0.0
	5	金	171	171	172	999	999	1,000	0.0	0.0	0.0
	6	±	172	171	173	1,000	1,000	998	0.0	0.0	0.0
	7	日		172	172		999	1,000		1.0	0.0
	8	月	169	170	171	1,000	1,000	1,000	1.0	1.0	1.0
	9	火		172	171		1,000	999		7.0	0.0
	10	水	171	172	172	1,000	1,000	1,002	0.0	0.0	0.0
	11	木		172	171		1,000	999		0.0	0.0
	12	金	171	171	172	1,000	1,000	1,000	0.0	0.0	0.0
	13	±	172	171	171	998	999	1,000	0.0	0.0	0.0
	14	日									
	15	祝									
	16	火		172	172		1,000	1,000		1.0	0.0
	17	水	171	171	171	1,000	1,000	1,000	0.0	0.0	0.0
	18	木		172	172		1,000	999		0.0	0.0
	19	金	171	171	172	1,000	1,000	1,000	0.0	0.0	0.0
	20	<u>±</u>									
	21	日									
	23	月	474	170	170	1 000	1 000	4 000		0.0	0.0
	24	祝	171	170	172	1,000	1,000	1,000	0.0	0.0	0.0
	25	水	172	173	172	1,000	1,000	999	0.0	0.0	0.0
	26	金	170	169	171	999	999	1,000	0.0	0.0	0.0
	27	<u></u>	171	171	172	1,000	1,000	1,000	10.0	0.0	0.0
	28	日	168	171	171	1,000	1,000	990	0.0	0.0	0.0
	29	 月	170	172	172	1,000	1,000	1,000	0.0	0.0	0.0
	30	火	170	172	172	1,000	1,000	1,000	0.0	1.0	0.0
		人		1 / 1	1/2		1,000	1,000		1.0	0.0
											3 A 41 34

有限会社 栄晃