

【施設維持管理情報 令和8年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日									
2 月	170	171	171	999	1,000	1,000	6.0	0.0	0.0
3 火		172	172		1,000	1,000		1.0	0.0
4 水	171	170	171	1,000	1,000	999	0.0	0.0	0.0
5 木		169	170		1,000	1,000		11.0	0.0
6 金	172	171	172	1,000	998	1,000	0.0	0.0	0.0
7 土	172	171	171	1,000	1,001	990	0.0	0.0	0.0
8 日		173	172		1,000	1,000		2.0	0.0
9 月	171	172	173	1,000	1,000	999	8.0	0.0	0.0
10 火		172	172		1,000	1,000		0.0	0.0
11 祝	171	172	172	1,000	1,002	1,000	1.0	0.0	0.0
12 木	172	172	173	999	999	1,000	3.0	1.0	0.0
13 金		172	170		1,000	1,000		0.0	0.0
14 土	171	171	172	1,000	1,000	1,000	1.0	0.0	0.0
15 日									
16 月	172	171	171	1,000	999	1,000	10.0	0.0	0.0
17 火		170	172		1,000	1,000		0.0	0.0
18 水	171	172	172	1,000	1,000	999	0.0	0.0	0.0
19 木		172	171		1,000	1,000		1.0	0.0
20 金	172	172	170	1,000	1,000	1,001	0.0	0.0	0.0
21 土	171	171	172	1,000	1,000	999	2.0	0.0	0.0
22 日	171	171	172	1,000	999	990	0.0	0.0	0.0
23 祝	169	171	172	1,000	1,000	1,000	0.0	0.0	0.0
24 火		172	171		1,000	1,000		3.0	0.0
25 水	172	172	173	1,000	1,000	1,000	0.0	0.0	0.0
26 木		174	172		999	1,001		0.0	0.0
27 金	172	171	171	1,000	1,000	1,000	1.0	0.0	0.0
28 土	173	171	172	999	999	1,000	1.0	0.0	12.0