

【施設維持管理情報 令和8年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日									
2 月	172	173	173	1,000	1,000	1,000	8.0	0.0	0.0
3 火		173	172		999	999		0.0	0.0
4 水	170	172	172	1,000	1,000	1,001	1.0	0.0	0.0
5 木		171	171		1,000	1,000		1.0	0.0
6 金	172	173	171	1,000	1,000	1,000	5.0	0.0	0.0
7 土	172	173	173	1,000	1,000	995	0.0	0.0	0.0
8 日	170	172	172	1,000	1,000	999	0.0	0.0	0.0
9 月	171	172	173	1,000	1,000	1,000	10.0	1.0	0.0
10 火		173	173		1,000	1,000		0.0	0.0
11 水	173	172	172	1,000	1,000	1,000	0.0	0.0	0.0
12 木		172	172		999	999		0.0	0.0
13 金	172	172	173	1,000	1,000	1,001	5.0	1.0	0.0
14 土	173	173	172	999	1,000	1,000	0.0	0.0	0.0
15 日									
16 月	172	172	173	1,000	1,000	1,000	7.0	2.0	0.0
17 火		171	172		998	999		0.0	0.0
18 水	170	171	174	1,000	1,000	1,000	0.0	0.0	0.0
19 木		172	173		1,000	1,000		0.0	0.0
20 祝	169	171	172	1,000	1,000	1,000	1.0	0.0	0.0
21 土	171	172	171	1,000	999	999	5.0	0.0	0.0
22 日									
23 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
24 火		172	173		1,000	1,000		0.0	0.0
25 水	172	173	172	999	1,002	1,000	1.0	0.0	0.0
26 木		172	172		1,000	1,000		0.0	0.0
27 金	170	171	173	1,000	1,000	1,000	0.0	0.0	0.0
28 土		172	172		1,000	1,000		0.0	0.0
29 日	172	171	173	1,001	1,000	1,000	3.0	1.0	1.0
30 月		172	172		1,000	999		0.0	0.0
31 火	170	172	173	1,000	1,000	1,000	0.0	0.0	1.0