

【施設維持管理情報 令和8年】

4月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	173	172	172	999	1,000	1,000	10.0	1.0	0.0
2 木		174	171		1,000	1,001		0.0	0.0
3 金	171	172	172	1,000	1,000	1,000	7.0	0.0	0.0
4 土	171	171	172	999	999	1,000	0.0	0.0	0.0
5 日									
6 月	174	173	173	1,000	1,001	1,001	1.0	0.0	0.0
7 火		173	172		1,000	1,000		12.0	0.0
8 水	172	172	171	1,000	1,000	999	9.0	0.0	0.0
9 木		169	170		999	1,000		0.0	0.0
10 金	172	171	172	1,000	1,000	1,001	0.0	0.0	0.0
11 土		172	173		1,000	1,000		1.0	0.0
12 日									
13 月	170	172	172	1,000	1,000	1,000	21.0	0.0	0.0
14 火		174	173		1,002	1,001		0.0	0.0
15 水	168	172	171	1,000	1,000	1,000	7.0	0.0	0.0
16 木		173	173		998	1,000		0.0	0.0
17 金	172	173	172	998	1,000	1,000	1.0	0.0	0.0
18 土	171	172	172	1,000	1,000	998	1.0	0.0	12.0
19 日									
20 月	173	174	172	1,000	1,000	1,000	0.0	0.0	0.0
21 火		172	173		1,000	1,001		0.0	0.0
22 水	173	172	172	1,000	1,000	1,000	12.0	2.0	0.0
23 木		173	172		998	999		0.0	0.0
24 金	172	172	173	1,000	1,000	1,000	10.0	0.0	0.0
25 土									
26 日									
27 月									
28 火									
29 祝									
30 木									