

【施設維持管理情報 令和8年】

6月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	170	172	173	1,000	1,000	1,000	1.0	0.0	0.0
2 火		169	171		999	1,000		0.0	0.0
3 水	171	172	173	1,000	1,001	1,000	12.0	0.0	0.0
4 木	172	172	173	1,000	999	999	0.0	0.0	0.0
5 金	173	173	172	1,000	1,000	1,000	17.0	1.0	0.0
6 土	172	173	174	1,000	1,001	1,000	0.0	0.0	0.0
7 日									
8 月	169	170	171	999	1,000	1,000	10.0	0.0	1.0
9 火	171	172	173	1,000	999	1,000	0.0	0.0	0.0
10 水	172	172	174	1,000	1,000	1,000	0.0	0.0	0.0
11 木	169	170	171	1,000	1,000	990	2.0	1.0	0.0
12 金	172	173	172	1,000	1,000	999	0.0	0.0	0.0
13 土	171	170	172	1,000	1,000	1,000	1.0	1.0	0.0
14 日									
15 月	172	172	171	1,000	1,000	999	0.0	0.0	0.0
16 火	170	171	172	1,001	1,000	989	1.0	1.0	0.0
17 水	171	172	173	1,000	1,000	1,000	3.0	1.0	0.0
18 木		169	171		1,000	1,000		0.0	0.0
19 金	171	172	172	1,000	999	1,001	0.0	0.0	0.0
20 土	172	172	171	1,000	1,000	998	7.0	1.0	10.0
21 日									
22 月	170	171	171	1,000	1,000	1,000	0.0	0.0	0.0
23 火		172	172		1,000	1,000		0.0	0.0
24 水	171	173	173	1,000	1,000	1,000	1.0	0.0	0.0
25 木	172	171	172	999	998	999	0.0	0.0	0.0
26 金	171	172	172	1,000	1,000	1,000	2.0	1.0	0.0
27 土	172	172	170	1,000	1,000	1,000	0.0	0.0	11.0
28 日									
29 月	171	172	172	1,000	1,001	1,000	0.0	0.0	0.0
30 火		171	172		1,000	1,000		1.0	0.0