

【施設維持管理情報 令和8年】

7月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	171	172	173	1,000	1,000	999	5.0	0.0	0.0
2 木	172	172	172	999	1,000	1,000	1.0	0.0	0.0
3 金	168	171	170	1,001	1,000	999	0.0	0.0	0.0
4 土		172	172		1,000	1,000		11.0	0.0
5 日									
6 月	169	172	171	1,000	1,000	1,000	0.0	0.0	0.0
7 火	173	173	172	998	1,000	1,000	0.0	0.0	0.0
8 水	172	172	171	1,000	1,001	1,000	1.0	0.0	0.0
9 木		170	172		1,000	1,000		0.0	0.0
10 金	173	173	172	1,000	1,000	1,000	0.0	0.0	0.0
11 土	172	172	171	1,000	1,000	990	0.0	0.0	11.0
12 日									
13 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
14 火		172	171		1,000	1,000		3.0	0.0
15 水	170	169	171	998	999	1,000	0.0	0.0	0.0
16 木		170	172		1,000	1,000		0.0	0.0
17 金	171	172	172	1,000	1,000	1,001	0.0	0.0	0.0
18 土	172	171	171	1,000	1,000	998	0.0	0.0	5.0
19 日									
20 祝	172	171	172	1,000	1,001	999	0.0	0.0	0.0
21 火	168	171	172	1,000	1,000	1,000	0.0	0.0	0.0
22 水	171	170	171	999	1,000	1,000	1.0	0.0	0.0
23 木		171	172		1,000	1,000		2.0	0.0
24 金	169	170	170	1,001	1,002	1,000	0.0	0.0	0.0
25 土	171	171	172	1,000	1,001	990	0.0	0.0	0.0
26 日									
27 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
28 火	170	169	171	1,000	999	1,000	0.0	0.0	0.0
29 水	171	172	170	999	1,000	1,000	0.0	0.0	0.0
30 木		171	170		1,000	1,000		10.0	0.0
31 金	169	172	171	1,000	1,000	1,000	0.0	0.0	0.0