

【施設維持管理情報 令和8年】

8月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00
1 土	170	171	171	1,000	1,000	990	1.0	0.0	0.0
2 日									
3 月	168	170	172	1,000	1,001	1,000	0.0	0.0	0.0
4 火	171	172	171	1,000	1,000	1,000	1.0	0.0	0.0
5 水	170	171	172	999	998	999	7.0	0.0	0.0
6 木		174	173		1,000	1,000		0.0	0.0
7 金	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
8 土	172	171	171	1,001	1,000	1,001	11.0	0.0	0.0
9 日									
10 月	170	171	170	1,000	1,000	999	0.0	0.0	0.0
11 祝	172	173	171	1,000	1,000	1,001	0.0	0.0	0.0
12 水	168	171	170	999	999	1,000	8.0	0.0	0.0
13 木		172	173		1,000	1,001		0.0	0.0
14 金									
15 土									
16 日									
17 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
18 火	172	173	172	1,000	1,000	1,000	0.0	0.0	0.0
19 水	171	171	170	999	1,000	1,001	5.0	0.0	0.0
20 木		171	171		1,000	999		0.0	0.0
21 金	172	170	172	1,000	999	1,001	0.0	0.0	0.0
22 土	173	171	172	1,000	1,000	1,000	0.0	0.0	7.0
23 日									
24 月	171	172	171	1,000	1,000	1,000	0.0	0.0	0.0
25 火	170	171	172	998	1,000	998	0.0	0.0	0.0
26 水	171	171	171	1,000	1,001	1,000	11.0	0.0	0.0
27 木		170	172		1,000	1,000		0.0	0.0
28 金	174	171	172	1,000	1,000	1,000	0.0	0.0	0.0
29 土	171	172	173	1,000	1,000	1,000	0.0	0.0	0.0
30 日									
31 月	169	172	172	1,000	1,000	1,000	0.0	0.0	0.0